CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

Job No.: CTCE/BBMP/W.No.06/KRIDL/WMM/Gradation/2014-15

07.05.2014

GRADATION FOR WMM
MORTH TABLE-400-11

Client : **Asst. Executive Engineer,** Byatarayanapura Sub Division, BBMP, Bangalore.

Agency : **Technical Manager - 1,** KRIDL, Bangalore.

Name of Work : Improvements and Asphalting to roads and drains at Rachenahalli Main Road near Thanisandra Govt. School in Ward No.06, Thanisandra Village Limints, BBMP, Bangalore.

Reference : AEE/BTP/(WO)/09/2014-15 Dated: 05.05.2014

Date of Testing : 07.05.2014

Material : WMM

Sample Location : WMM Mix Plant

Oven Dry Wt (gm): **25400**

Is Sieve Size in mm	Weight Retained (gm)	Cumulative Weight Retained (gm)	Cumulative % of Retained	Cumulative % of Passing	Spec.Limits
53	0	0	0	100	100
45	990	990	3.9	96.1	95-100
22.4	6235	7225	28.4	71.6	60-80
11.2	5125	12350	48.6	51.4	40-60
4.75	4180	16530	65.1	34.9	25-40
2.36	3745	20275	79.8	20.2	15-30
0.600	2380	22655	89.2	10.8	8-22
0.075	2460	25115	98.9	1.1	0-8

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 15 days from the date of testing.

Civil-Tech Consultants & Engineers Bangalore

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ
ಬಿಬಿಎಂಪಿ, ಬೆಂಗಳೂರು 24